

Date 11/13/80

Permit No. 80-104

# TOWN OF ACTON

## APPLICATION FOR PERMIT TO CONSTRUCT WITHIN A PUBLIC WAY

This application must be submitted not less than five (5) days prior to any Construction within a public way.

Notice 24 hours in advance of any construction must be given to the Town Engineer.

1. Permittee: BOLTON CORP Address: 119 PARKER ST ACTON
2. Location of Proposed Construction: .....
3. Purpose of Construction: WATER SUPPLY FOR TENNEY CIRCLE
4. Length of Cut: 22'-24'
5. Width of Cut: 4'
6. Width of Existing Pavement: 22-24'
7. Type of Existing Roadway Surface: ASPHALT Type of Curb: NONE
8. Type of Existing Sidewalk Surface: NONE Type of Shoulder: .....
9. Date of Street Opening: From 11-13-80 To 12-1-80

I, the undersigned, hereby declare that I have read and agree to the Town of Acton Specifications for Regulating Construction with Public Ways dated February 4, 1969. I have deposited the required bond with the Town of Acton, and I covenant and agree that the Town may deduct from this amount the cost of repairs to the road surface, curbs, shoulders, walls or other features within the right-of-way including replacing bounds if not completed by me to the satisfaction of the Town Engineer within the specified time.

Witness my hand and seal,

Signature of Applicant: Bolton Corp

Special Instructions:

Backfill must be selected gravel compacted by mechanical means in 6" lifts or puddled with sufficient water to insure complete compaction.

The permanent patch must be placed by December 1, 1980. The posted bond will be held until April 15, 1981 at which time the cut will be inspected for settlement. Any settlement must be corrected prior to release of the bond.

INSP. 3/13/81 D.A.

① NO PERM. PATCH.

② LOAM REMOVAL (DEXTER E HARPELL) 369-6141

Permit Issued: Date NOV. 13, 1980 By: D. Abbott

Application Denied: Date .....

Work Inspected and Approved: Date .....

Fee \$5.00 AS PER MEMO of 11-17-81

(over)

D. Abbott  
ASSIST TOWN ENGR